Board: Robert Janes-Chairman, Blake Seale-Member
Absent: Thomas Fahey-Member & Jane Krafton-Admin. Assistant
Health Agent: Paul Sevigny
Admin Asst: N/A
Others in Attendance: Richard Barthelmes, PE - Cornerstone.

R. Janes, Chair called meeting to order at 2:40pm.

I. <u>LANDFILL BUSINESS:</u>

The Board was concerned with several things with regards to the design of the cutoff trench. They were as follows:

- 1) depth of trench,
- 2) location of trench,
- 3) whether field changes could be made without creating a problem.

There was an error in the invert elevations of the perforated pipe. He said his intent was to have the trench at 5' max. It was discussed that the trench could be closer to the edge of pavement to avoid damage to the trees and stone wall. Field changes could be made to the approved plan, and an as-built plan would be needed.

Richard was hoping to get the revised plan back to the Board sometime next week July 15th. The Board will review prior to submitting to DEP for approval.

Next Meeting Scheduled:

July 23, 2019 – 4:30 pm Second Floor - Health Agent's Office 1910 Office Building 381 Main Street, West Newbury MA

Meeting Adjourned 3:15pm